

# SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134  
 Tel. (708) 544-3260 • Toll Free (800) 783-LABS  
 Fax (708) 544-8587  
 www.suburbanlabs.com

**Client ID:** Zion-Concord

**Project Name:** Drinking Water Lead Analysis

**Report Date:** March 04, 2019

**Workorder:** 1902A03

**Analyte:** Lead

**Method:** EPA 200.8

**Matrix:** Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1902A03-001A	Mrs. Hoy's Room; 1-12A Draw	ND	2.00	µg/L	2/14/19 20:40	2/15/2019	2/21/2019
1902A03-002A	Mrs. Hoy's Room; 1-12A Flush	ND	2.00	µg/L	2/14/19 20:40	2/15/2019	2/21/2019
1902A03-003A	Church Lunge; 1-04A Draw	33.0	2.00	µg/L	2/14/19 20:40	2/15/2019	2/21/2019
1902A03-004A	Church Lunge; 1-04A Flush	14.1	2.00	µg/L	2/14/19 20:40	2/15/2019	2/21/2019
1902A03-005A	Kitchen; Northwest Sink Draw	ND	2.00	µg/L	2/14/19 20:40	2/15/2019	2/21/2019
1902A03-006A	Kitchen; Northwest Sink Flush	ND	2.00	µg/L	2/14/19 20:40	2/15/2019	2/21/2019
1902A03-007A	Kitchen; Southwest Sink Draw	ND	2.00	µg/L	2/14/19 20:40	2/15/2019	2/21/2019
1902A03-008A	Kitchen; Southwest Sink Flush	ND	2.00	µg/L	2/14/19 20:40	2/15/2019	2/21/2019
1902A03-009A	Drinking Fountain; 2-13 Draw	27.1	2.00	µg/L	2/14/19 20:40	2/15/2019	2/21/2019
1902A03-010A	Drinking Fountain; 2-13 Flush	17.2	2.00	µg/L	2/14/19 20:40	2/15/2019	2/21/2019
1902A03-011A	Mrs. Lardi's Room; 2-14 Draw	42.3	2.00	µg/L	2/14/19 20:40	2/15/2019	2/21/2019
1902A03-012A	Mrs. Lardi's Room; 2-14 Flush	2.05	2.00	µg/L	2/14/19 20:40	2/15/2019	2/21/2019
1902A03-013A	Mrs. Volk's Room; 2-13 Draw	34.7	2.00	µg/L	2/14/19 20:40	2/15/2019	2/21/2019
1902A03-014A	Mrs. Volk's Room; 2-13 Flush	27.0	2.00	µg/L	2/14/19 20:40	2/15/2019	2/21/2019